

Ref #	Brief description	Who	Update/comments and suggested STATUS
4611	RIMNET data at individual collection sites to be circulated to enable understanding.	EA	Information is published. EA requested to assist in obtaining local data per site. Radioactive Incident Monitoring data now called Radiological Response & Emergency Management System (RREMS). Network of gamma dose rate monitoring sites reported quarterly by coordinates, so not easy for members of the public to understand. Ambient gamma radiation dose rates across the UK - GOV.UK (www.gov.uk)
4833 12/10/23	Request for Sohail to update on the new campaign for wet ILW.	SA SZA and JR ONR	Sohail Ashraf to update on the wet ILW campaign Will ask the programme team to attend an SSG later in the year, or early next year. - OPEN
4835	Request for update on water and sewage output	Peter Reynolds EA	Answer questions regarding water and sewage output. Chair to check with stakeholders regarding outstanding questions OPEN
4848 (c) 15/03/23	Additional information requested on the concentration levels in the disinfectant incident and worst-case scenario if not detected.	EA for SZB	Alex Lord to provide - OPEN
4860 (a)	Subgroup to be held to review Gov consultation on radioactive waste management.	SSG/NDA	Awaiting information on plans to reclassify waste streams. Has been replaced with GGR (new regulation levels) further information to be circulated by Chair/Secretariate and sub group meeting date agreed. OPEN
4873 (a) 29/06/23	Accredited disposal route for LLW from SZA?	Sohail Ashraf	Guy Esnouf noted the LLW deposit in Cumbria was the home for most of the national LLW, but the government was consulting on different ways of classifying waste. SA agreed to find out and confirm back for SZA LLW. OPEN
4873 (b)	Confirm the work to cap off the sewage and waste lines at the rigs.	Sohail Ashraf	Sohail Ashraf stated that to his knowledge those lines had been capped off, and he would come back with confirmation.

4873 (c)	Sohail Ashraf to explore the truth of a blog claiming hazards to health from dust and water	Sohail Ashraf	Noted that planned demolition was over a year away, and if suppression systems were needed then water testing would take place. Mike Taylor to provide content of blog to SA. OPEN
4875	EA to provide further information re: the frequency of discharge into the sea and the process for notification.	JH SZA EA	Radiological liquid waste collected into tanks at SZA, and when full it was sealed and tested prior to any release, information was requested on the frequency of discharge into the sea and the process for notification. OPEN
4878	RWM to confirm % of HLW area at GDF would be allocated for Spent fuel	RWM	Question to be forwarded for response. OPEN
4888 (a) 01/11/23	EDF to review minimising traffic during the SZB outage work in 2024.	EDF	Noted additional workforce on site during the outage in 2024. Robert Gunn said there would be 1,300 people on site during the day. Agreed to consider options and to report back. OPEN
4888(b)	Contact Suffolk County Council to report the flooding area on the B1119 by Saxmundham Road.	EDF SZB	As part of Emergency planning and next Sizewell Emergency Planning Consultative Committee (SEPCC) meeting. OPEN
4890	Information requested on SZC proposal to use SZB water effluence for its water strategy	Nikki Rousseau	SZB EDF NR agreed to forward question to the SZC Office and report back. OPEN
4891	Confirmation requested of NDA vision for SZA end state following the Department for Energy Security and Net Zero (DESNZ) proposal to re-categorise waste	Sohail Ashraf	NDA draft business plan now published and as of 04/12 open for consultation. OPEN
4894	NDA and/or NRS to be asked to confirm funding agreement with EDF for AGR decommissioning and fuel storage.	BH/NRS and NDA	Project Ruby is the agreement with UK Gov and EDF to share costs of decommissioning. Further information requested as national Chairs meeting with NRS Board members. OPEN

OUTSTANDING ACTIONS FOR PROGRESSION WITH REGULATORS/OTHERS

Ref #	Brief description	Who	Update/comments and suggested STATUS
4610	Report sent to SA to be forwarded to PHE to comment re: impact of low level radiation on public health	Chair and PHE	Public Health England was replaced by UK Health Security Agency and Office for Health Improvement and Disparities. East of England regional contact identified, awaiting reply to questions.
4657	Taishan – damage to fuel rods, EDF requested to circulate report when received. (New concerns reported 06/12/23)	Robert Gunn EDF	We have no further information, when more information becomes available, we will share with the SSG
4847 (a) 15/03/23	DG to contact SZC colleagues regarding IRSN report & EPR to provide to Members.	DG ONR SZB	To be discussed with DG at Regulator update meeting
4848 (b)	PW to forward BMJ article on Low Level Radiation to EA Alex Lord, for EA comment	PW/EA and UKHSA	Provided. Awaiting comment from UK Health Security Agency.
4848 (d)	Request for update on desalination plant to be powered by SZB	EA for SZB/EDF	

CLOSED ACTIONS

Ref number	Brief description	Who responsible	Update/comments and suggested STATUS
4604 (3)	Are staff/contractors told about the Radiological Disease compensation scheme?	SA and RG	Yes, on the internet and also promoted by Magnox and Trade Unions. CLOSED
4604 (4)	What is SZA annual budget?	SA	NDA produce annual accounts, projects not necessarily site specific spend. See link on attached document. We can request more information on specific elements if required – Information available through the annual accounts provided by the NDA CLOSED
4604 (5)	What is latest plan for Graphite core decommissioning?	SA	Using info from lead-and-learn site of Trawsfynydd. Shall we ask for a report? When there is more information available from the development and implementation of the Trawsfynydd strategy in future years, we will share this CLOSED
4662	Where was fuel rod manufactured that developed pin hole?	RG	We are unable to determine the source. It's either a BNFL or Siemens (Framatome) sourced assembly. CLOSED
4670	ISI for control rod mechanism and other questions – to be answered	RG	This has been answered comprehensively - responses provided to SSG in 2022 as per attached - CLOSED
4671	What public consultation on revised REPPiR emergency planning requirements?	RG	The extraordinary SSG meeting has taken place where Neal Evans came along to outline the off-site plan - CLOSED
4672 (ii)	Would SZB work with SCC Highways regarding speed limit on Lovers Lane	RG	This is a matter for Leiston Town Council to pursue with the Highway Authority (SCC). LTC reps on SSG could request LTC to consider. CLOSED
4673	Prof Henderson report (small fish in cold water system) – comments needed from EA and SZB	CW to provide, AL & RG to respond	Report and question forwarded to EDF and EA for comment. See Response to 4749 CLOSED

4776	SZB to confirm date of next fuel (full or partial) cycle.	Sean Verrall & Richard Parlone	Refuelling Outage 19 is planned to take place in October 2024. CLOSED
4777	Check whether EDF was contributing to the NLF.	Sean Verrall	EDF has been contributing to the Nuclear Liabilities fund – please see attached report. CLOSED
4846 (a)	Confirmation of future of DSL building and if this could be made available for community use.	SZB	District Survey Lab is on land owned and managed by EDF Energy Nuclear Generation Ltd. The building houses telecommunications systems that are still required for the foreseeable future. CLOSE
4846 (b)	Request for map of EDF estate, boundaries and indication of relocated facilities	SZB	Relocated Facilities maps provided. Upper Abbey Farm is not included. CLOSE
4846 (c)	Update on the Freedom Group maintenance plan for land	SZB	EDF's Land & Biodiversity Management Team, supported by Freedom Group, are responsible for managing the Sizewell B estate and SSSI. Freedom Group have been working with EDF fleet-wide, delivering 'environmental land management' since 2014. CLOSE
4846 (d)	RG to circulate weld inspection report to Members	SZB	SZBs last outage included a number of inspections: Stress Corrosion Cracking inspections; these are ultrasonic inspections of over 20 locations around the reactor coolant system to determine whether the phenomena experienced on some French reactors was relevant to Sizewell B. Structural Weld overlay; this involved a number of ultrasonic inspections of areas of pipework that had been subject to pre-emptive weld overlay, to demonstrate the quality of the welds. Follow-on inspections of the Thermal Sleeves that were replaced in the previous outage. In total around 500 inspections, ranging from visual, ultrasonic, eddy current, magnetic particle, dye-penetrant and radiographic

			inspections were conducted in the outage. All work was conducted by experienced and qualified inspectors. All inspection results were satisfactory and supported the return to service of the reactor for a further cycle of operation. The results were reported off-site to the ONR as part of our Safety Case to operate the plant for the next cycle, and ONR subsequently issued their formal consent to start-up based on their assessment of this case. CLOSE
4846 (e)	Update on health and management of seals, and actions to prevent reoccurrence	SZB	Two seals were released, one remains. Animal welfare agencies have advised regarding management. During outage drivers inspected but no obvious holes or reason could be found. CLOSE
4846 (f)	Confirmation of roof design for new response centre (green?)	SZB	Yes, sedum roof – see Sizewell B report. CLOSE
4846 (h)	Chair to enquire of ESC regarding planning permission for soil heap area and lighting plan	SSG	Is included within DCO for SZC. ESC monitor. CLOSE
4846 (i)	Request for SZC to attend and update on relevant matters	ALL	EDF SZC has refused to attend. SZC Forum is currently not meeting. Visit Office in Leiston or telephone any questions. CLOSED transferred to SZC Forum
4624	SZA land NDA to provide lease & freehold docs prior to meetings with Land team	J McN/NDA Land team	Presentations made at meetings in 2022 and 2023. Update June 2023 - Relicensing is progressing to enable land transfer. CLOSE
4749	Clarification required - SZB regulators to respond in relation to fish monitoring requirements.	Peter Reynolds	The Environment Agency does not regulate the intake, but rather the discharge. Sizewell B is not required by its environmental permits to carry out ongoing monitoring of fish impingement or entrainment. EA do not undertake ongoing monitoring of fish

			impingement or entrainment, but the determination of permits and the DCO require assessment under the Habitats Regulations – as is being done for the prospective Sizewell C site. Information on fish impingement and entrainment at Sizewell B was collected by CEFAS on behalf of Sizewell C. CLOSE
4806	Investigate alternatives to plastic barriers	SA	SZA sustainability team are looking at other options to the plastic barriers with respect to the future. As other projects come into flight, the sustainability team will be liaised with in advance. CLOSE
4810	Request for presentation of the Turbine Hall demolition from Sohail.	SA	Presentation and Q&As sent and circulated. Team attended SSG meeting to present on progress. CLOSE for now and reopen when next milestones are approached.
4821	Request to arrange attendance at SSG/presentation by Nuclear Waste Services on the GDF and waste disposal	John McNamara	Guy Esnouf, the Director of Communications for NWS attended and presented at June 2023 meeting. CLOSE
4681	Near shore surveys and update by EDF Energy & attendance requested re: SZC overlap issues	Secretariat to invite	Request sent to EDF who declined to attend. CLOSED to be forwarded to SZC Forum.
4737	Clarification required on planning for SZB relocation facilities	Carolyn Barnes	EDF provided formal notice they were switching to the second relocated facilities consent (DC/20/4646/FUL) in July 2022, they will be implementing the second consent. EDF's letter of notification is on Public Access under DC/20/4646/FUL. A. There are currently two applications in relating to the Sizewell B relocated facilities application; reserved matters for the welfare and admin buildings (DC/22/2823/ARM) and a discharge of condition application (DC/22/2822/DRC) – both of which relate to the second relocated facilities application, the one EDF will be implementing. EDF are still awaiting a reserved matters application for the visitor centre, submission date not known. We currently have an application in for discharge of condition 12 in

			relation to landscaping to the west of the Western Access Road, which will likely be positively determined in the next few weeks (DC/22/5001/DRC – can be viewed on Public Access). EDF are progressing the second relocated facilities application (DC/20/4646/FUL) following notification of the switch from the first permission to the second permission in summer 2022. CLOSED
4846 (g)	Request to monitor and report back on additional light pollution – including from car park	SZB and Naomi Gould ES Planning Team	Request that anyone with future concerns documents and reports these. CLOSED
4848 (a)	Chair to send instructions on how to join EA stakeholder list to Members	SSG	Information provided to join EA stakeholder list for updates and to attend webinar. CLOSED
4857 (a)	Video of Bradwell site, how it managed its risk, requested.	SA	Will be provided at future SSG meeting. CLOSED
4861 (a)	Request for update on fish management at SZB and proposals for SZC	EDF SZB and SZC	Information provided by SZB. Transferred to SZC Forum. CLOSED
4868 (a)	SN to provide presentation and response regarding Magnox SZA residual waste stored at Sellafield at next meeting	SN/RWM	Presentation provided. Residual waste was stored after reprocessing ceased. CLOSED
4876	Chair/Secretariate to recirculate the answer on EDF's contribution to the nuclear liability fund	MF	Provided. CLOSED